

## SPECIAL CONDITIONS

1. This consent to operate is valid for operating the facility for the manufacture of products (Col. 2) at the rate (Col. 3) mentioned below. Any change in the products and its quantity has to be brought to the notice of the Board and fresh consent has to be obtained.

Sl. No.	Description	Quantity	Unit
<b>Product Details</b>			
It's a health care facility giving treatment to the patients as follows;			
	In patient	08	Nos./Day
	Out patient	312	Nos./Day
	Bed strength	36	Nos.

2. This consent to operate is valid for operating the facility with the below mentioned permitted Outlets for the discharge of sewage/trade effluent. Any change in the outlets and the quantity has to be brought to the notice of the Board and fresh consent has to be obtained.

Outlet No.	Description of Outlet	Maximum daily discharge in KLD	Point of disposal
<b>Effluent Type : Sewage</b>			
	Sewage	2.4	On Industries own land
<b>Effluent Type : Trade Effluent</b>			
	Trade Effluent	1.5	After disinfection let in to Septic Tank

3. The effluent discharge shall not contain constituents in excess of the tolerance Limits as laid down hereunder.

			TOLERANCE LIMITS - OUTLETS -Nos			
			Sewage	Trade Effluent		
1	pH	--				
2	Temperature	°C	5.5 to 9			
3	Particle size of Suspended solids	--	--			
4	Total Suspended Solids	mg/l	30			
5	Total Dissolved solids (inorganic)	mg/l	--			
6	Oil & Grease	mg/l	--			
7	Biochemical Oxygen Demand (3 days at 27°C)	mg/l	20			
8	Chemical Oxygen Demand	mg/l	--			
9	Chloride (as Cl)	mg/l	--			
10	Sulphates (as SO <sub>4</sub> )	mg/l	--			
11	Total Residual Chlorine	mg/l	--			
12	Ammonical Nitrogen (as N)	mg/l	--			
13	Total Kjeldahl Nitrogen (as N)	mg/l	--			
14	Free Ammonia (as NH <sub>3</sub> )	mg/l	--			
15	Arsenic (as As)	mg/l	--			
16	Mercury (as Hg)	mg/l	--			
17	Lead (as Pb)	mg/l	--			
18	Cadmium (as Cd)	mg/l	--			
19	Hexavalent Chromium (as Cr+6)	mg/l	--			
20	Total Chromium (as Cr)	mg/l	--			
21	Copper (as Cu)	mg/l	--			
22	Zinc (as Zn)	mg/l	--			