

HOPE ULTRA SYSTEMS

No: 2/79, MAIN ROAD, MAMSAPURAM (PO),
SIVAKASI, VIRUDHUNAGAR-626124.
E-mail : hopeultrasystems@gmail.com

GSTIN: 33DLMPK3057D1Z9
Mobile: +919487402761, +919715223192.

CALIBRATION CERTIFICATE

Requested By
GUPHC, SIVAKASI.

Scope:

Equipment Name : Semi Auto Analyzer	Asset no : PHC/SVKS-LAB/001
Make : ROBONIK	Calibration Done at : customer place
Model : Prie test Touch	Calibration Date : 21/08/2023
Sl no : AT0550511RBK	Next call due on : 20/08/2024

Wave length	Film type	Range	Absorbance obtained
340mm	HP	0.333-0.361	0.334
	DP	1.164-1.253	1.185
	TP	1.658-1.782	1.669

Wave length	Film type	Range	Absorbance obtained
405mm	DP	0.661- 708	0.6643
	3DP	1.943-2.098	1.966
	TP	1.006-1.077	1.015
	2TP	1.932-2.099	1.957

Wave length	Film type	Range	Absorbance obtained
510mm	HP	0.161-0.173	0.165
	DP	0.647-0.695	0.654
	3DP	1.910-2.081	1.919
	TP	0.969-1.036	0.983

Wave length	Film type	Range	Absorbance obtained
545mm	HP	0.154-0.165	0.156
	SP	0.304-0.321	0.316
	DP	0.595-0.629	0.601
	TP	0.903-0.956	0.917

Wave length	Film type	Range	Absorbance obtained
578mm	DP	0.576-0.616	0.582
	3DP	1.657-1.857	1.676
	TP	0.867-0.922	0.875
	3TP	2.549-2.738	2.555

Wave length	Film type	Range	Absorbance obtained
630mm	HP	0.162-0.176	0.164
	DP	0.653-0.712	0.661
	TP	1.043-1.116	1.050
	2TP	2.099-2.166	2.025

Error Acceptance : Not Applicable (user defined)
Equipment Status : Working in Good condition

